



Product Service

CERTIFICATE

No. B 13 04 22856 010

Holder of Certificate: Mibu Denki Industrial Co.,Ltd.50 Nikinomori-cho, Kisshouin
Minami-ku, Kyoto 601-8354
JAPAN**Production Facility(ies):** 22856**Certification Mark:****Product:** Terminal block
Protective Conductor Terminal Block**Model(s):** MBT-30AE-xP-yyy, MBT-60AE-xP-yyy
x (any number 1 to 99) denote Number of Poles
yyy (max. 3 digit of any alphanumeric
or blank)denote Manufacturer's optional
control code**Parameters:**
Rated cross section: 6 mm²
(for MBT-30AE-xP-yyy)
16 mm²
(for MBT-60AE-xP-yyy)
Degree of protection: IP20**Remarks:**
When installing / inserting the equipment, all
requirement of the mentioned test standard must
be fulfilled.**Tested according to:** EN 60947-7-2:2009

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 73542146**Date,** 2013-04-08
Page 1 of 1
(Shigehisa Ishikawa)